

Certificate of constancy of performance

according to Regulation (EU) No. 305/2011



Certificate No.: 1008-CPR-MC 69265612 0004

Report No.: 28253612 003

Applicant: Huzhou Shangfu Wire & Cable High Technology Co., Ltd.
No. 688, Jingye Road, 313000 Huzhou, Zhejiang, P.R. CHINA

Manufacturer: Huzhou Shangfu Wire & Cable High Technology Co., Ltd.
No. 688, Jingye Road, 313000 Huzhou, Zhejiang, P.R. CHINA

Manufacturing plant: Huzhou Shangfu Wire & Cable High Technology Co., Ltd.
No. 688, Jingye Road, 313000 Huzhou, Zhejiang, P.R. CHINA

Product: Photovoltaic cable family

Identification: H1Z2Z2-K 1×2,5mm² to 1×25mm² (B2_{ca})
Intended use: Electric Cables for general applications
FPC Report No.: HU23Q6WL 001

System of assessment and verification: 1+

Tested according to: EN 50575:2014+A1:2016

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performance described in Annex of the above standard(s) under above system are applied and the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 2020-07-28 and it will remain valid until the test methods and/or factory production control requirements included in the standard, used to assess the performance of the declared characteristics, and the product, and the manufacturing conditions in the plant are unchanged. The manufacturing plant and factory production control system of the manufacturer is supervised regularly by the Certification Body.

Certification Body

Date of issue:
Budapest, 2023-08-23

A handwritten signature in blue ink, appearing to read 'László Kocsis', with a horizontal line underneath.

László Kocsis

TÜV Rheinland InterCert Kft., Product Certification Body — H-1143 Budapest, Gizella út 51-57. — www.tuv.com
Product certification body accredited by NAH under No NAH-6-0053/2018/K, Notified Body No. 1008

Validity of certificate can be checked on www.CERTIPEDIA.com

Azonosító / Identification	Védjegy / Trade Mark	Tűzvédelmi Osztály / Reaction to Fire classification
H1Z2Z2-K 1×2,5 mm ²	FRCABLE	B2 _{ca} -s1a,d0,a1
H1Z2Z2-K 1×4 mm ²	FRCABLE	B2 _{ca} -s1a,d0,a1
H1Z2Z2-K 1×6 mm ²	FRCABLE	B2 _{ca} -s1a,d0,a1
H1Z2Z2-K 1×10 mm ²	FRCABLE	B2 _{ca} -s1a,d0,a1
H1Z2Z2-K 1×16 mm ²	FRCABLE	B2 _{ca} -s1a,d0,a1
H1Z2Z2-K 1×25 mm ²	FRCABLE	B2 _{ca} -s1a,d0,a1


TÜVRheinland[®]**Certification Body****Date of issue:**

Budapest, 2023-08-23


.....
László Kocsis